



Jeb Bush
Governor

Department of Environmental Protection

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Colleen M. Castille
Secretary

May 4, 2005

Mr. Peter Van Fossen
Solidification Products International, Inc.
1536 Rolling Meadow Drive
Valrico, Florida 33594

RE: The Petro-Barriers™, Petro -Plug™, & Petro-Pipe™

Dear Mr. Fossen:

The Bureau of Petroleum Storage Systems has concluded its review of your request dated April 28, 2005 that was submitted for above referenced products.

Based upon the submitted third party documents, the use of the above referenced products are acceptable in the State of Florida for direct discharge of water from diked field areas as required in Rule 62-762-701(2)(c), Florida Administrative Code.

If you need additional information, please call Farid Moghadam at 850/245-8848.

Sincerely,

John P. Svec, P.E.
Storage Tank Regulation Section

JPS/FGM/fm

CC: Districts and Local Tank Program Offices